

- [1] **1<sup>st</sup> Addition to  
EC-TYPE EXAMINATION CERTIFICATE IBExU09ATEX1133**  
according to Directive 94/9/EC, Annex III  
(Translation)



- [2] Equipment: **Vibration Level Switches**  
Type DP\*\*0 StEx
- [3] Manufacturer: HYCONTROL LTD.
- [4] Address: Orchard Street  
Redditch, Worcestershire B98 7DP  
UNITED KINGDOM

[5] **Addition/Modification**

The Vibration Level Switches mentioned in [2] can be marked in accordance with the current standards mentioned under [7].

[6] **Test report**

The proof of the explosion protection of the equipment mentioned in [2] is documented in the test report IB-12-3-141 of 30 May 2012. The test documents are part of the test report.

[7] **Test result**

IBExU certifies that the equipment mentioned in [2] has been found to comply with the Essential Health and Safety Requirements given in the Directive 94/9/EC by compliance with EN 60079-0:2009 and EN 60079-31:2009.

The equipment mentioned in [2] fulfils the requirements of the explosion protection for the Equipment Group II, Category 1/2 D in type of protection protection by enclosure.  
The marking of the equipment mentioned in [2] shall include the following:

II 1/2 D Ex ta/tb IIIC T95 °C Da/Db  
-20 °C ≤ T<sub>a</sub> ≤ +60 °C

**This addition is only valid in connection with the EC-Type Examination Certificate IBExU09ATEX1133 of 1 October 2009.**

IBExU Institut für Sicherheitstechnik GmbH  
Fuchsmühlenweg 7 - 09599 Freiberg, Germany  
☎ +49 (0) 3731 3805-0 - ☎ +49 (0) 3731 23650

Authorised for certifications

Freiberg, 30 May 2012

- Explosion protection -

By order

  
(Dipl.-Ing. Willamowski)



Certificates without signature and seal are not valid.  
Certificates may only be duplicated completely and unchanged.  
In case of dispute, the German text shall prevail.